
RIVIERA UTILITIES MOBILE HOME SERVICE SPECIFICATIONS Minimum 30 ft. Class 6 Treated Wood Pole

Less Than 5 Years Old

NOTE These specs are Riviera's minimum requirements

CONTACT LOCAL CITY INSPECTION DEPTS. FOR ADDITIONAL REQUIREMENTS.



Breaker Panel **Optional** Weatherproof Receptacle Shall Have GFI Protection 00 Line Side Neutral Load Side

Riviera Utilities will supply meter sockets, as available, or customers may provide their own. Meter sockets shall have the following general specifications:

- Raintight, NEMA 3R rated
- UL Listed
- Painted Aluminum is preferred, but if unavailable painted steel and unpainted aluminum are acceptable
- Ringless meter sockets are preferred but ring type are acceptable
- No locking provision is required
- House power panels may be allowed with prior approval from Riviera Utilities

Warning stickers will be applied to the outside of the meter socket by Riviera at the time a meter is set.

| Design Parameters: | REV. | DESC. | DATE | RIVIERA UTILITIES |
|--------------------|------|---------------|-----------|--|
| | - 1 | Meter Sockets | 6/10/2022 | 400/04077 077 00077 4 777 4 777 4 777 |
| | | | | 120/240V SECONDARY, 1 PHASE, |
| | | | | MOBILE HOME SERVICE |
| | | | | |
| | | | | 100 / 200 AMPS |
| | | | | |
| | | | | DRAWN BY: S. TIRADOR CHKD BY: APP'D BY: DATE: 6/10/22 Q2.1G |
| | | | 4/13 | APP'D BY: DATE: 6/10/22 Q2.1G |